

A Product Technical Statement (PTS) is a way to show how a product or system is fit for purpose for use in New Zealand and to demonstrate compliance with the New Zealand Building Code (Building Code Amendment Act 2013).

## Product description

Designed in New Zealand, and made in China, Rinnai mains pressure enamel hot water cylinders are available in five sizes; 30 L, 50 L, 180 L, 250 L, and 300 L. Model and configuration\* selection will be dependent on the hot water demand of the property.

\* Refer to the Rinnai website or cylinder specification guide for the cylinder configurations available.

## Scope of use

Suitable for indoor mains and low pressure residential and commercial applications. The system should be located and arranged so as to achieve the closest proximity to water draw off points.

They are not suitable as a spa, swimming pool heater, or for solar applications.

Hard or acidic water will need to be treated to use this product.

To meet the New Zealand Building Code requirement<sup>1</sup> to disinfect water for legionella bacteria, the cylinder thermostat has been set to 65 °C.

<sup>1</sup> Clause G12.3.9, Acceptable Solution G12/AS1 6.14.3

## Design guidelines

Specification and installation must be in accordance with Rinnai installation requirements and with the Building Code.

Rinnai specify that installation must be in compliance with AS/NZS 3000:2007, and AS/NZS 3500.

As per AS/NZS 3500.4:2015 5.4 and G12/AS1 6.11.3, the cylinder **MUST BE** installed with a suitably drained drip tray/catch pan.

## Quality assurance

- ISO 9001 Certified System
- ISO 14001 Certified System



30 L

50 L



180 L

250 L



300 L



ISO 9001



www.intlcert.com



Experience our innovation

### Compliance with the NZ Building Code

If specified, installed and maintained in accordance with all Rinnai requirements the Rinnai mains pressure enamel cylinders will comply with the below provisions of the NZ Building Code.

| Code clause  | Evidence of compliance  |
|--------------|---|
| G9.2, G9.3.3 | Cylinder approval to AS/NZS 60335.2.27  |
| G12.3.8      | Cylinder approval to AS/NZS 60335.2.27  |
| G12.3.9      | Acceptable solution G12/AS1 6.14.3, the cylinder thermostat has been set to 65°C.   |
| H1.3.4       | Cylinders meet the requirements of the minimum energy performance standards (MEPs) by cylinder approval to NZS 4606 (Storage water heaters - General requirements), and AS/NZS 4692.1:2005 (Electric water heaters - Energy consumption, performance and general requirements). |

### Additional evidence to support the above statements

Supplier Declaration of Compliance:

- SDoC identification number - 2017 002 EN

Electrical safety approval:

- Certificate of approval number - ESV170064

### Seismic restraint

Cylinders should be installed on a flat level base of sufficient strength to support the weight of the water heater when full. The water heater must also be suitably restrained against seismic activity, 'G12/AS1 Figure 14' details an acceptable method of restraint.

### Special conditions - installation requirements

Full appliance information can be found at [www.rinnai.co.nz](http://www.rinnai.co.nz).

Limitations: To be installed in accordance with all Rinnai installation requirements and by a licensed gasfitter/plumber, and electrician. Upon completion of the installation, a final inspection and test to demonstrate that the cylinder has been installed in accordance with Rinnai's instructions is to be done by the installer. The installer is to issue an electrical safety certificate upon completion.

### Special conditions - maintenance requirements

For reliable operation Rinnai cylinders should be maintained and serviced as detailed in the owner and installer guide. Installation, servicing and repair shall be carried out only by authorised personnel.